

Use Grade 60 epoxy-coated reinforcing bars. Provide 2 inches minimum cover. Anchor all reinforcement to prevent movement. Secure each section at the front, back, and at 3'-6' intervals using a method approved by the Engineer.

- 1 Where abutting sections are placed as separate pours, a butt joint may be used. Extend longitudinal reinforcement into the abutting section a minimum of 3 feet.
- 2 Use 1 inch diameter deformed dowel bars of sufficient length to ensure 6 inch minimum embedment in barrier and supporting surface. Install dowels either in supporting surface when placed, or in drilled holes using polymer grout complying with Materials I.M. 491.11 or hydraulic cement grout complying with Materials I.M. 491.13.
- 3 Fillet all exposed corners with a $\frac{3}{4}$ inch dressed and beveled strip.
- 4 Construct concrete footing when barrier is not placed on concrete slab. Apply Article 2403.03 of the Standard Specifications, but the use of forms is optional. If forms are used, place backfill around the completed footing.
- Place barrier markers at 100 foot increments in areas with non-continuous lighting, or 250 foot increments in areas with continuous lighting. Marker color to be the same as adjacent edge line.
- 6 When connecting to BA-107, include 6 additional #5 bars embedded a minimum of 3 feet into the BA-105 barrier. Evenly transition rebar over length of transition section.

Possible Contract Item:
Concrete Barrier, BA-105 or
Concrete Barrier, BA-105 and Footing

Possible Tabulation: 108-18B

