



- ① Thickness same as pipe thickness (T) but not less than 4 inches (except for corrugated pipe where "T" may vary).
- ② Opening between pipes shall be carefully grouted.
- ③ Minimum reinforcing shall be steel wire mesh 6" x 6" - W2 No. 8 wire - 30 lbs./100 sq. ft. Lap ends 6 inches.
- ④ Positive type joint coupling required.
- ① Thickness of wall of concrete pipe. See Standard Road Plan RF-1.

(2000 D and 3000 D Pipe)



CONSTRUCTION OF TYPE 'C' CONCRETE ADAPTORS FOR PIPE CULVERT CONNECTIONS