



Refer to **DR-104** for minimum and maximum allowable cover (H) for the particular kind of pipe culvert.

- 1 The backfill adjacent to and above the pipe culvert may be placed in conjunction with normal embankment construction. Thoroughly tamp the embankment within the limits shown.
- 2 Take extra care to ensure complete and satisfactory tamping of backfill material in the area immediately adjacent to the lower portion of pipe.
- 3 Carefully shape excavation below groundline either using a template conforming to actual dimension and shape of the pipe or using other means. If using other means, check with a template conforming to the actual dimension and shape of the pipe.
- 4 For culverts backfilled by flooding, place a cohesive soil plug at the inlet, outlet, and, when necessary, sides, prior to flooding.
- 5 4-inch Porous Backfill bedding, 2-inch Floodable Backfill bedding may be used under unsealed rigid pipe.
- 6 Extend Porous Backfill through the outlet end soil plug when used for bedding.
- 7 Quantity calculations are based upon a 1:1 slope and minimum trench dimension. Actual slope of trench may vary based upon Contractor's operations.
- 8 Ground Line at time of pipe installation. When existing ground exceeds 5 feet depth over pipe, backfill and compaction by flooding is not required more than 5 feet above the pipe.
- 9 Where a corrugated metal pipe culvert requiring elongation is to be installed (to counteract deformation caused by backfill), complete elongation using a means approved by the Engineer. Elongation may be developed either as part of shop fabrication or field installation. Install with elongated axis vertical.

Possible Contract Items:
Flowable Mortar
Flooded Backfill
Excavation, Class 20

Possible Tabulations:
104-3
104-4

IOWA DOT	REVISION	
	1	04-19-16
	STANDARD ROAD PLAN	
DR-101		SHEET 1 of 1

REVISIONS: Changed W to D in TRENCH INSTALLATION drawings.

Brian Smith
APPROVED BY DESIGN METHODS ENGINEER

**PIPE CULVERT
(BEDDING AND BACKFILL)**

Denotes pay limits for flooded backfill