

**TABLE A****Price Adjustment for Aggregate Gradation Test Deviation**

<b>Specified Sieve Size</b>	<b>Deviation in Percent Passing</b>	<b>PCC</b>
<b>% Contract Unit Price Adjustment</b>		
<b>19 mm, 26.5 mm, 37.5 mm (3/4", 1", 1½")</b>	<b>0.1 – 5.0</b>	<b>1</b>
	<b>5.1 +</b>	<b>2</b>
<b>4.75 mm, 9.5 mm, 13.2 mm (#4, 3/8", ½")</b>	<b>0.1 – 4.0</b>	<b>1</b>
	<b>4.1 – 7.0</b>	<b>2</b>
	<b>7.1 +</b>	<b>3</b>
<b>2.36 mm thru 150 µm (#8 thru #100)</b>	<b>0.1 – 3.0</b>	<b>1</b>
	<b>3.1 – 5.0</b>	<b>2</b>
	<b>5.1 – 7.0</b>	<b>3</b>
	<b>7.1 +</b>	<b>4</b>
<b>75 µm (#200)</b>	<b>0.1 – 0.5</b>	<b>1</b>
	<b>0.6 – 1.0</b>	<b>2</b>
	<b>1.1 – 2.0</b>	<b>3</b>
	<b>2.1 – 4.0</b>	<b>4</b>

**PCC**

For Structural Concrete, when a lot verification sample is non-complying, the limits of the non-complying material will be determined by testing previous and subsequent lot verification samples. The quantity of material identified as being non-complying will be price adjusted per column PCC in Table A.

For non-QM-C Paving and the #200 sieve for QM-C paving, when the lot verification sample is non-complying, the limits of the non-complying material will be identified by testing previous and subsequent samples within the lot. The quantity of material identified as being non-complying will be price adjusted per column PCC in Table A.

**Application of Price Adjustment**

1. All percent passing (and average percent passing) values are to be calculated to two significant figures.
2. The Price Adjustment percentage (to be applied to the quantity of non-complying material) is the sum of percentages determined for individual out-of-tolerance sieve sizes.
3. For PCC Overlays, the Price Adjustment applies to both the Furnish and Place items.

