



# SINGLE REINFORCED CONCRETE BOX CULVERT STANDARDS

## GENERAL NOTES:

- THE RCB CULVERT SECTIONS ARE DESIGNED FOR HL-93 LIVE LOAD AND EARTH FILLS OF VARYING HEIGHTS.
- THE RCB CULVERT SECTIONS ARE DESIGN FOR CLASS I EXPOSURE CONDITIONS EXCEPT: CLASS 2 EXPOSURE CONDITION IS UTILIZED FOR THE SLAB DESIGN IN 0' FILL INSTANCES.
- ALL SLAB AND FLOOR REINFORCING STEEL IS TO BE SUPPORTED AT INTERVALS OF NOT MORE THAN 3'-0" IN EITHER DIRECTION AS OUTLINED IN THE STANDARD SPECIFICATIONS.
- THE CLEAR DISTANCE FROM FACE OF CONCRETE TO NEAR EDGE OR END OF REINFORCING BAR TO BE 2" UNLESS OTHERWISE NOTED.
- EXCEPT FOR DOWEL BARS 5" IN SLAB, LONGITUDINAL REINFORCING IS NOT TO EXTEND THRU THE CONSTRUCTION JOINTS.
- FLOOR OF BARREL IS TO BE FINISHED SMOOTH. SIDES OF FOOTING ARE TO BE FORMED TO INSURE CORRECT LINE AND GRADE.
- THE PERMISSIBLE CONSTRUCTION JOINT AT THE TOP OF THE WALLS MAY BE LOWERED AT THE CONTRACTOR'S OPTION WITH ENGINEER'S APPROVAL.
- THE REINFORCEMENT SUPPLIED FOR THIS STRUCTURE SHALL BE GRADE 60 REINFORCEMENT IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS. THE DESIGN STRESSES ARE BASED ON GRADE 60 REINFORCEMENT.
- THE VERTICAL BARS IN THE WALLS MAY BE SPLICED ABOVE THE FOOTING AT THE CONTRACTOR'S OPTION AS FOLLOWS:

BAR SIZE NUMBER	4	5	6	7	8	9
MINIMUM SPLICE LENGTH	17"	21"	25"	31"	41"	51"

THIS SPLICE, IF USED, WILL BE AT THE CONTRACTOR'S EXPENSE.

- REINFORCING BAR CLEARANCES WILL BE AS FOLLOWS:

EDGE CLEARANCES:	2" EXCEPT
TOP OF FLOOR	2 1/4" TO NEAR TRANSVERSE REINFORCING BAR
BOTTOM OF FLOOR	3 1/4" TO NEAR TRANSVERSE REINFORCING BAR
END CLEARANCES:	
VERTICAL TOP	2"
VERTICAL BOTTOM	3" OR 3 1/2" IF OVERALL HEIGHT OF THE CULVERT IS NOT TO A FULL INCH
TRANSVERSE	2"

- ALL CONSTRUCTION JOINTS SHALL BE FORMED WITH A BEVELED KEYWAY EXCEPT AT BELL JOINTS.
- ALL BEVELED KEYWAYS SHALL BE CENTERED.
- KEYWAY SIZE SHALL BE 2x4 EXCEPT AS FOLLOWS:  
KEYWAY BETWEEN THE FLOOR AND WALL SHALL BE 2x6 WHEN THE WALL IS GREATER THAN 10 INCHES WIDE.
- KEYWAY DIMENSIONS SHOWN ON THE PLANS ARE BASED ON NOMINAL DIMENSIONS UNLESS STATED OTHERWISE. IN ADDITION, THE BEVEL USED ON THE KEYWAY SHALL BE LIMITED TO A MAXIMUM OF 10 DEGREES FROM VERTICAL.
- IF 0' OF FILL IS SPECIFIED, DETAILS FOR PAVING NOTCH AND REFERENCE TO EPOXY COATING OF SLAB REINFORCING STEEL, IF APPLICABLE, SHALL BE INCLUDED IN THE FINAL PLANS.
- ALL DIMENSIONS ARE IN FEET AND INCHES UNLESS OTHERWISE NOTED OR SHOWN.
- CONCRETE FORMS ARE REQUIRED TO REMAIN IN PLACE 5 DAYS OR LONGER IN ACCORDANCE WITH ARTICLE 2403.03, M, 2, OF THE STANDARD SPECIFICATIONS, EXCEPT THE MINIMUM CONCRETE FLEXURAL STRENGTH REQUIRED BEFORE REMOVAL OF FORMS SHALL BE 575 PSI.
- THESE CULVERT STANDARDS LABEL ALL REINFORCING STEEL WITH ENGLISH NOTATION (5#) IS 5/8 INCH DIAMETER BAR), ENGLISH REINFORCING STEEL RECEIVED IN THE FIELD MAY DISPLAY THE FOLLOWING "BAR DESIGNATION". THE "BAR DESIGNATION" IS THE STAMPED IMPRESSION ON THE REINFORCING BARS, AND IS EQUIVALENT TO THE BAR DIAMETER IN MILLIMETERS.

ENGLISH SIZE	4	5	6	7	8	9
BAR DESIGNATION	13	16	19	22	25	29

- IN THE EVENT THE SLAB THICKNESS AT THE BARREL END SECTION EXCEEDS 20 INCHES, THE CULVERT PARAPET SHALL EXTEND A MINIMUM OF 6 INCHES ABOVE THE TOP OF THE CULVERT SLAB. REFER TO THE CULVERT DESIGN MANUAL FOR INSTRUCTIONS. THESE DETAILS ARE TO BE INCLUDED IN THE DESIGN PLANS TO ADDRESS THESE SITUATIONS.

## INDEX FOR SINGLE CULVERT STANDARDS:

RCB	INDEX & GENERAL NOTES
RCB G1-12	TYPICAL CULVERT BARREL DETAILS
RCB G2-12	CULVERT BARREL DETAILS, 3 x 3 BARREL SECTIONS
RCB 3-3-12	CULVERT BARREL DETAILS, 4 x 4 BARREL SECTIONS
RCB 4-4-12	CULVERT BARREL DETAILS, 5 x 3 BARREL SECTIONS
RCB 5-3-12	CULVERT BARREL DETAILS, 5 x 4 BARREL SECTIONS
RCB 5-4-12	CULVERT BARREL DETAILS, 5 x 5 BARREL SECTIONS
RCB 5-5-12	CULVERT BARREL DETAILS, 5 x 6 BARREL SECTIONS
RCB 5-6-12	CULVERT BARREL DETAILS, 6 x 3 BARREL SECTIONS
RCB 6-3-12	CULVERT BARREL DETAILS, 6 x 4 BARREL SECTIONS
RCB 6-4-12	CULVERT BARREL DETAILS, 6 x 5 BARREL SECTIONS
RCB 6-5-12	CULVERT BARREL DETAILS, 6 x 6 BARREL SECTIONS
RCB 6-6-12	CULVERT BARREL DETAILS, 6 x 7 BARREL SECTIONS
RCB 6-7-12	CULVERT BARREL DETAILS, 6 x 8 BARREL SECTIONS
RCB 6-8-12	CULVERT BARREL DETAILS, 8 x 4 BARREL SECTIONS
RCB 8-4-12	CULVERT BARREL DETAILS, 8 x 5 BARREL SECTIONS
RCB 8-5-12	CULVERT BARREL DETAILS, 8 x 6 BARREL SECTIONS
RCB 8-6-12	CULVERT BARREL DETAILS, 8 x 7 BARREL SECTIONS
RCB 8-7-12	CULVERT BARREL DETAILS, 8 x 8 BARREL SECTIONS
RCB 8-8-12	CULVERT BARREL DETAILS, 8 x 9 BARREL SECTIONS
RCB 8-9-12	CULVERT BARREL DETAILS, 8 x 10 BARREL SECTIONS
RCB 8-10-12	CULVERT BARREL DETAILS, 10 x 4 BARREL SECTIONS
RCB 10-4-12	CULVERT BARREL DETAILS, 10 x 5 BARREL SECTIONS
RCB 10-5-12	CULVERT BARREL DETAILS, 10 x 6 BARREL SECTIONS
RCB 10-6-12	CULVERT BARREL DETAILS, 10 x 7 BARREL SECTIONS
RCB 10-7-12	CULVERT BARREL DETAILS, 10 x 8 BARREL SECTIONS
RCB 10-8-12	CULVERT BARREL DETAILS, 10 x 9 BARREL SECTIONS
RCB 10-9-12	CULVERT BARREL DETAILS, 10 x 10 BARREL SECTIONS
RCB 10-10-12	CULVERT BARREL DETAILS, 10 x 11 BARREL SECTIONS
RCB 10-11-12	CULVERT BARREL DETAILS, 10 x 12 BARREL SECTIONS
RCB 10-12-12	CULVERT BARREL DETAILS, 12 x 4 BARREL SECTIONS
RCB 12-4-12	CULVERT BARREL DETAILS, 12 x 5 BARREL SECTIONS
RCB 12-5-12	CULVERT BARREL DETAILS, 12 x 6 BARREL SECTIONS
RCB 12-6-12	CULVERT BARREL DETAILS, 12 x 7 BARREL SECTIONS
RCB 12-7-12	CULVERT BARREL DETAILS, 12 x 8 BARREL SECTIONS
RCB 12-8-12	CULVERT BARREL DETAILS, 12 x 9 BARREL SECTIONS
RCB 12-9-12	CULVERT BARREL DETAILS, 12 x 10 BARREL SECTIONS
RCB 12-10-12	CULVERT BARREL DETAILS, 12 x 11 BARREL SECTIONS
RCB 12-11-12	CULVERT BARREL DETAILS, 12 x 12 BARREL SECTIONS
RCB 12-12-12	PARALLEL WING HDWLS., 0° SKEW, DIMENSION TABLE
PWH 0-1-12	PARALLEL WING HDWLS., 0° SKEW, CROSS SECTION DETAILS
PWH 0-2-12	PARALLEL WING HDWLS., 0° SKEW, WINGWALL ELEV. & BOTT. APRON REINF.
PWH 0-3-12	PARALLEL WING HDWLS., 0° SKEW, TOP APRON REINF.
PWH 0-4-12	PARALLEL WING HDWLS., 0° SKEW, QUANTITY TABULATION, 12'-0" SPAN
PWH 0-5-12	PARALLEL WING HDWLS., 0° SKEW, QUANTITY TABULATION, 10'-0" SPAN
PWH 0-6-12	PARALLEL WING HDWLS., 0° SKEW, QUANTITY TABULATION, 8'-0" SPAN
PWH 0-7-12	PARALLEL WING HDWLS., 0° SKEW, QUANTITY TABULATION, 6'-0" SPAN
PWH 0-8-12	PARALLEL WING HDWLS., 0° SKEW, QUANTITY TABULATION, 5'-0" SPAN
PWH 0-9-12	PARALLEL WING HDWLS., 15° SKEW, DIMENSION TABLE
PWH 15-1-12	PARALLEL WING HDWLS., 15° SKEW, CROSS SECTION DETAILS
PWH 15-2-12	PARALLEL WING HDWLS., 15° SKEW, WINGWALL ELEV. & BOTT. APRON REINF.
PWH 15-3-12	PARALLEL WING HDWLS., 15° SKEW, TOP APRON REINF.
PWH 15-4-12	PARALLEL WING HDWLS., 15° SKEW, QUANTITY TABULATION, 12'-0" SPAN
PWH 15-5-12	PARALLEL WING HDWLS., 15° SKEW, QUANTITY TABULATION, 10'-0" SPAN
PWH 15-6-12	PARALLEL WING HDWLS., 15° SKEW, QUANTITY TABULATION, 8'-0" SPAN
PWH 15-7-12	PARALLEL WING HDWLS., 15° SKEW, QUANTITY TABULATION, 6'-0" SPAN
PWH 15-8-12	PARALLEL WING HDWLS., 15° SKEW, QUANTITY TABULATION, 5'-0" SPAN
PWH 15-9-12	PARALLEL WING HDWLS., 30° SKEW, DIMENSION TABLE
PWH 30-1-12	PARALLEL WING HDWLS., 30° SKEW, CROSS SECTION DETAILS
PWH 30-2-12	PARALLEL WING HDWLS., 30° SKEW, WINGWALL ELEV. & BOTT. APRON REINF.
PWH 30-3-12	PARALLEL WING HDWLS., 30° SKEW, TOP APRON REINF.
PWH 30-4-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 12'-0" SPAN
PWH 30-5-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 10'-0" SPAN
PWH 30-6-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 8'-0" SPAN
PWH 30-7-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 6'-0" SPAN
PWH 30-8-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 5'-0" SPAN
PWH 30-9-12	PARALLEL WING HDWLS., 30° SKEW, QUANTITY TABULATION, 5'-0" SPAN

## INDEX FOR SINGLE CULVERT STANDARDS (CONT'D):

PWH 45-1-12	PARALLEL WING HDWLS., 45° SKEW, DIMENSION TABLE
PWH 45-2-12	PARALLEL WING HDWLS., 45° SKEW, CROSS SECTION DETAILS
PWH 45-3-12	PARALLEL WING HDWLS., 45° SKEW, WINGWALL ELEV. & BOTT. APRON REINF.
PWH 45-4-12	PARALLEL WING HDWLS., 45° SKEW, TOP APRON REINF.
PWH 45-5-12	PARALLEL WING HDWLS., 45° SKEW, QUANTITY TABULATION, 12'-0" SPAN
PWH 45-6-12	PARALLEL WING HDWLS., 45° SKEW, QUANTITY TABULATION, 10'-0" SPAN
PWH 45-7-12	PARALLEL WING HDWLS., 45° SKEW, QUANTITY TABULATION, 8'-0" SPAN
PWH 45-8-12	PARALLEL WING HDWLS., 45° SKEW, QUANTITY TABULATION, 6'-0" SPAN
PWH 45-9-12	PARALLEL WING HDWLS., 45° SKEW, QUANTITY TABULATION, 5'-0" SPAN
CBJ 1-12	CULVERT BELL JOINTS, 3', 4' & 5' SPANS
CBJ 2-12	CULVERT BELL JOINTS, 6' & 8' SPANS
CBJ 3-12	CULVERT BELL JOINTS, 10' & 12' SPANS
CBJ 4-12	CULVERT BELL JOINTS, ALL SPANS

## SPECIFICATIONS:

### DESIGN:

AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS, 5TH ED., SERIES OF 2010.

### CONSTRUCTION:

IOWA DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS FOR HIGHWAY AND BRIDGE CONSTRUCTION, CURRENT SERIES, PLUS APPLICABLE GENERAL SUPPLEMENTAL SPECIFICATIONS, DEVELOPMENTAL SPECIFICATIONS, SUPPLEMENTAL SPECIFICATIONS AND SPECIAL PROVISIONS

## DESIGN STRESSES:

DESIGN STRESSES FOR THE FOLLOWING MATERIALS ARE IN ACCORDANCE WITH THE AASHTO LRFD BRIDGE DESIGN SPECIFICATIONS, 5TH ED., SERIES OF 2010: REINFORCING STEEL IN ACCORDANCE WITH AASHTO LRFD SECTION 5, GRADE 60. CONCRETE IN ACCORDANCE WITH AASHTO LRFD SECTION 5, f'c = 4.0 KSI.

10-12 LATEST REVISION DATE	 APPROVED BY BRIDGE ENGINEER	 <b>Iowa Department of Transportation</b> Highway Division
		STANDARD DESIGN <b>SINGLE REINFORCED CONCRETE BOX CULVERTS</b> APRIL, 2012
		<b>INDEX &amp; GENERAL NOTES</b>

RCB G1-12