

Sampling & Testing Guide-Minimum Frequency

October 21, 2008
Supersedes October 16, 2007

BASE REPAIR (2212), PAVEMENT REPAIR (PATCHES) Sections 2529 & 2530

Matls. IM 204
Appendix T

MATERIAL OR CONSTRUCTION ITEM	TESTS	METHOD OF ACCEPTANCE & RELATED IMs	QUALITY CONTROL					INDEPENDENT ASSURANCE & VERIFICATION S&T						REMARKS
			SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	S&T TYPE	SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	
SOURCE INSPECTION														
Aggregates Fine (4110)		AS 209												
Aggregates Coarse (4115)		AS 209												
Portland Cement (4101)	Quality	AS 401												
Fly Ash (4108)	Quality	AS 491.17												
GGBFS (Ground Granulated Blast Furnace Slag)	Quality	AS 491.14												
Curing Compound (4105)	Lab Tested	405												
Air Entraining Admixture (4103)	Quality	AS 403												
Granular Backfill	Gradation Quality	AS CERT												
Drain Tubing	Quality	AS 443												
Epoxy Grout		AS 491.11												
Joint Seal (4136.02)	Lab Tested	436.01 AS 436.02												
Backer Rod (4136.02)		AS 436.04												
Steel Reinforcing	Quality	AS 451												
AS-Approved Source ASD-Approved Shop Drawing S&T-Sampling & Testing			Cert A-Type A Certification Cert C-Type C Certification Cert D-Type D Certification					RCE-Resident Construction Engineer/Project Engineer DME-District Materials Engineer CTRL-Central Materials Office CONTR-Contractor					IA-Independent Assurance V-Verification	

Sampling & Testing Guide-Minimum Frequency

October 21, 2008
Supersedes October 16, 2007

BASE REPAIR (2212), PAVEMENT REPAIR (PATCHES) Sections 2529 & 2530

Matls. IM 204
Appendix T

MATERIAL OR CONSTRUCTION ITEM	TESTS	METHOD OF ACCEPTANCE & RELATED IMs			QUALITY CONTROL					INDEPENDENT ASSURANCE & VERIFICATION S&T						REMARKS
					SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	S&T TYPE	SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	
PLANT INSPECTION																
Aggregates-Coarse (4115)	Grad	302	306	336	CONTR	1/lot	IM 301	CONTR		V	RCE/ CONTR	1 st day +20%	IM 301	RCE		
	Moist			308	CONTR	1 / half day	1000 gm	CONTR								
	Sp. Gr.			307	CONTR	IM 527	1000 gm	CONTR								
	Quality	AS			209											
Aggregate- Fine (4110)	Gradation			302, 306 336	CONTR	1/lot	IM 301	CONTR	830211	V	RCE/ CONTR	1 st day+ 20%	IM 301 IM 301	RCE		
	Moisture			308, 528	CONTR	1/lot	1000 gm	CONTR	830211						See IM 528 if Moisture Probe is used	
	Sp. Gr.			307	CONTR	IM 528	1000 gm	CONTR	830211							
	Quality	AS			209											
Portland Cement (4101)	Quality	AS		CERT D		Each Load										
Fly Ash	Quality	AS		CERT D		Each Load										
Air Entraining Admixture		AS		403						V	DME	1/batch	1 pt	CTRL	Sample lots not previously reported or as directed by DME	
Water Reducing Admixture		AS		403						V	DME	1/batch	1 pt	CTRL		
Retarding Admixture		AS		403						V	DME	1/batch	1 pt	CTRL		
AS-Approved Source ASD-Approved Shop Drawing S&T-Sampling & Testing					Cert A-Type A Certification Cert C-Type C Certification Cert D-Type D Certification CONTR-Contractor					RCE-Resident Construction Engineer/Project Engineer DME-District Materials Engineer CTRL-Central Materials Office					IA-Independent Assurance V-Verification	

Sampling & Testing Guide-Minimum Frequency

October 21, 2008
Supersedes October 16, 2007

BASE REPAIR (2212), PAVEMENT REPAIR (PATCHES) Sections 2529 & 2530

Matls. IM 204
Appendix T

MATERIAL OR CONSTRUCTION ITEM	TESTS	METHOD OF ACCEPTANCE & RELATED IMs		QUALITY CONTROL					INDEPENDENT ASSURANCE, & VERIFICATION S&T						REMARKS
				SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	S&T TYPE	SAMPLE BY	FREQ.	SAMPLE SIZE	TEST BY	REPORT	
GRADE INSPECTION															
Uncompacted HMA Mixture		Scale ticket with JMF number													Job Mix Formula (JMF) approved by DME
Plastic Concrete	Air Slump	318	327						V	RCE	1/30 cy		RCE		Minimum 1 per pour
Reinforcing Steel Epoxy-Coated Steel	Quality Quality	AS	451		Each Shipment										
Calcium Chloride	Concentr.		373	RCE	1/lot		RCE								
Smoothness for Compacted HMA or Hardened Conc. (2529.10)			341	CONTR			CONTR								Approval by DME See Plans/Specs for exclusions
AS-Approved Source ASD-Approved Shop Drawing S&T-Sampling & Testing				Cert A-Type A Certification Cert C-Type C Certification Cert D-Type D Certification				RCE-Resident Construction Engineer/Project Engineer DME-District Materials Engineer CTRL-Central Materials Office CONTR-Contractor						IA-Independent Assurance V-Verification	