

2'-0"

MANUFACTURER TO SPECIFY PROPER BOLT SPACING AND CONDUIT LOCATIONS.

FRONT DOOR OF CABINET

GROUND ROD 3" TO 6" BELOW GROUND LEVEL

1" GROUND WIRE DUCT

CABINET DEPTH + 6"

30"

30"

CABINET WIDTH + 6"

ANCHOR BOLTS (AS SPECIFIED BY MFR. OF CABINET)

CONDUIT AS SHOWN ON PLANS

EXPANSION MATERIAL

4"

3' MIN.

1'-0"

4" APRON

INSTALL NO. 6 BARE COPPER GROUND CONDUCTOR FROM INTERNAL GROUNDING NUT TO GROUND ROD CLAMP.

GROUND ROD 5/8" X 8'

REV.	DATE	BY	CONTROLLER CABINET FOOTING (TYPE 170 CONTROLLER)	FIGURE: 8010.2
	01-01-98			SHEET 1 OF 1

REV.	DATE	BY	CONTROLLER CABINET FOOTING (TYPE 170 CONTROLLER)	FIGURE: 8010.2
DATE: 01-01-98				SHEET 1 OF 1